



Keystone Certifications, Inc.  
 1790 Old Trail Road, Suite D  
 Etters, PA 17404 / Phone 717-932-8500

## Notice of Product Certification Authorization

### National Fenestration Rating Council

**Issued To:**

Manufacturer: Best Window & Door Co.  
 Address: 332 Strayer St.  
                   Johnstown                  PA          15906  
 NFRC Code: BES  
 Cert Date: 3/1/2006

<b>Certification Number</b>
3638
<b>Product Line Number</b>
BES - K - 003

**The Following NFRC Product Line Has Been Authorized For Certification:**

Model / Series: 3300/4300 Double Slider  
 Operator Type: HSXX  
 Frame Type: VY  
 Sash Type: VY  
 Exp. Date: 5/21/2007

**Ratings Authorized For Certification:**

Rating	Property	Authorized
NFRC 100	U-factor	<input checked="" type="checkbox"/>
NFRC 200	Solar Heat Gain Coefficient	<input checked="" type="checkbox"/>
NFRC 200	Visible Light	<input checked="" type="checkbox"/>
NFRC 400	Air Leakage	<input type="checkbox"/>
NFRC 500	Condensation Resistance	<input checked="" type="checkbox"/>

**Conditions And Criteria For Product Certification Authorization:**

Manufacturer Agrees To The Following Conditions And Criteria Per The NFRC PCP:

- 3.1A Products are marketed consistent to the simulated products.
- 3.1B Waiver requests shall be submitted to IA prior to marketing new products.
- 3.1C Only products with labels shall be considered certified.
- 3.1D Only products authorized for certification shall be labeled.
- 3.1E Manufacturer shall designate individual responsible for the proper labeling.
- 3.1F Manufacturer shall not use labels that are false, inaccurate or misleading.
- 3.2A Manufacturer shall maintain a documented in-plant quality control program.
- 3.2B Quality control records shall be maintained for 4 years.
- 3.2C Manufacturer shall have staff to properly inspect and maintain quality control records.
- 3.3.1 A, B Manufacturer agrees to the proper use of temporary and permanent labels.
- 3.3.1 C Manufacturer shall have temporary labels approved prior to printing.
- 3.5 Manufacturer agrees to obtain permission from NFRC to use the NFRC Certification Mark.

***Attached are the Certification Authorization Reports printed from the NFRC database.  
 The Manufacturer is authorized to label the options listed in the reports.  
 Please notify Keystone of any errors or omissions within 10 days of receipt.***

Authorized Signature: \_\_\_\_\_

Due diligence was used in authorizing these products for certification. By accepting this report the licensee agrees to hold harmless and indemnify Keystone Certifications, Inc. from all claims or liabilities which may arise based on this certification authorization. Certification authorization is based on NFRC program requirements and simulation and test reports from accredited laboratories.

# NFRC Product Certification Authorization Report



**IA:** Keystone Certifications, Inc.

**Manufacturer:** Best Window and Door Company  
**Product Series:** 3300/4300 Double Slider  
**Simulation Lab:** SEEL  
**Test Date:** 5/21/2003  
**Revised Date:** 1/4/2006  
**Air Leakage:**

**Street:** 332 Strayer Street  
**Type:** Horizontal Slider  
**Simulation Report Date:** 7/8/2004  
**Initial Certification Date:** 3/1/2006  
**Expiration Date:** 5/21/2007

**City/State/Zip:** Johnstown, PA 15906  
**CPD Number:** BES-K-3  
**Simulation Report Number:** BWI401w-b1-A1  
**Re-Certification Date:**  
**Print Date:** 03/01/2006

Status	Prod. Num.	Mfr. Code	Frame/Sash	Glaz. Layers	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Condens. Resist.
	00001	Clr 2.5/air/Clr 2.5, ss, 3 1/4" frame	VY	2		0.6870	OF-S	AIR	N		LE	0.44	0.56	0.59	46
	00001-00001	Clr 2.5/air/Clr 2.5, ss, 3 1/4" frame, div	VY	2		0.6870	OF-S	AIR	G	0.75	LE	0.44	0.50	0.52	46
	00001-00002	Clr 2.5/air/Clr 2.5, ss, 4 9/16" frame	VY	2		0.6870	OF-S	AIR	N		LE	0.44	0.56	0.59	46
	00001-00003	Clr 2.5/air/Clr 2.5, ss, 4 9/16" frame, div	VY	2		0.6870	OF-S	AIR	G	0.75	LE	0.44	0.50	0.52	46
	00001-00004	Clr 3/air/Clr 3, ss, 3 1/4" frame	VY	2		0.6250	OF-S	AIR	N		LE	0.44	0.54	0.58	46
	00001-00005	Clr 3/air/Clr 3, ss, 3 1/4" frame, div	VY	2		0.6250	OF-S	AIR	G	0.75	LE	0.44	0.49	0.52	46
	00001-00006	Clr 3/air/Clr 3, ss, 4 9/16" frame	VY	2		0.6250	OF-S	AIR	N		LE	0.44	0.54	0.58	46
	00001-00007	Clr 3/air/Clr 3, ss, 4 9/16" frame, div	VY	2		0.6250	OF-S	AIR	G	0.75	LE	0.44	0.49	0.52	46
	00002	SB60 2.5/air/Clr 2.5, ss, 3 1/4" frame	VY	2	0.035 (2)	0.6870	OF-S	AIR	N		LE	0.31	0.28	0.52	59
	00002-00001	SB60 2.5/air/Clr 2.5, ss, 3 1/4" frame, div	VY	2	0.035 (2)	0.6870	OF-S	AIR	G	0.75	LE	0.31	0.25	0.46	59
	00002-00002	SB60 2.5/air/Clr 2.5, ss, 4 9/16" frame	VY	2	0.035 (2)	0.6870	OF-S	AIR	N		LE	0.31	0.28	0.52	59
	00002-00003	SB60 2.5/air/Clr 2.5, ss, 4 9/16" frame, div	VY	2	0.035 (2)	0.6870	OF-S	AIR	G	0.75	LE	0.31	0.25	0.46	59
	00002-00004	SB60 3/air/Clr 3, ss, 3 1/4" frame	VY	2	0.035 (2)	0.6250	OF-S	AIR	N		LE	0.31	0.28	0.52	59
	00002-00005	SB60 3/air/Clr 3, ss, 3 1/4" frame, div	VY	2	0.035 (2)	0.6250	OF-S	AIR	G	0.75	LE	0.31	0.25	0.46	59
	00002-00006	SB60 3/air/Clr 3, ss, 4 9/16" frame	VY	2	0.035 (2)	0.6250	OF-S	AIR	N		LE	0.31	0.28	0.52	59
	00002-00007	SB60 3/air/Clr 3, ss, 4 9/16" frame, div	VY	2	0.035 (2)	0.6250	OF-S	AIR	G	0.75	LE	0.31	0.25	0.46	59
	00003	SB60 2.5/arg/Clr 2.5, ss, 3 1/4" frame	VY	2	0.035 (2)	0.6870	OF-S	ARG	N		LE	0.28	0.28	0.52	62
	00003-00001	SB60 2.5/arg/Clr 2.5, ss, 3 1/4" frame, div	VY	2	0.035 (2)	0.6870	OF-S	ARG	G	0.75	LE	0.28	0.25	0.46	62

**NFRC Product Certification Authorization Report**

**IA:** Keystone Certifications, Inc.

**Manufacturer:** Best Window and Door Company  
**Product Series:** 3300/4300 Double Slider

**Street:** 332 Strayer Street  
**Type:** Horizontal Slider

**City/State/Zip:** Johnstown, PA 15906  
**CPD Number:** BES-K-3

Status	Prod. Num.	Mfr. Code	Frame/Sash	Glaz. Layers	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Condens. Resist.
	00003-00002	SB60 2.5/arg/Clr 2.5, ss, 4 9/16" frame	VY	2	0.035 (2)	0.6870	OF-S	ARG	N		LE	0.28	0.28	0.52	62
	00003-00003	SB60 2.5/arg/Clr 2.5, ss, 4 9/16" frame, div	VY	2	0.035 (2)	0.6870	OF-S	ARG	G	0.75	LE	0.28	0.25	0.46	62
	00003-00004	SB60 3/arg/Clr 3, ss, 3 1/4" frame	VY	2	0.035 (2)	0.6250	OF-S	ARG	N		LE	0.28	0.28	0.52	62
	00003-00005	SB60 3/arg/Clr 3, ss, 3 1/4" frame, div	VY	2	0.035 (2)	0.6250	OF-S	ARG	G	0.75	LE	0.28	0.25	0.46	62
	00003-00006	SB60 3/arg/Clr 3, ss, 4 9/16" frame	VY	2	0.035 (2)	0.6250	OF-S	ARG	N		LE	0.28	0.28	0.52	62
	00003-00007	SB60 3/arg/Clr 3, ss, 4 9/16" frame, div	VY	2	0.035 (2)	0.6250	OF-S	ARG	G	0.75	LE	0.28	0.25	0.46	62
	00004	Clr3/air/RLE3, ss3 3 1/4" frame	VY	2	0.027 (3)	0.6250	OF-S	AIR	N		CL	0.31	0.34	0.51	59
	00004-00001	Clr3/air/RLE3, ss3 3 1/4" frame	VY	2	0.027 (3)	0.6250	OF-S	AIR	G	0.75	CL	0.31	0.31	0.45	59
	00004-00002	Clr3/air/RLE3, ss3 4 9/16" frame	VY	2	0.027 (3)	0.6250	OF-S	AIR	N		CL	0.31	0.34	0.51	59
	00004-00003	Clr3/air/RLE3, ss3 4 9/16" frame	VY	2	0.027 (3)	0.6250	OF-S	AIR	G	0.75	CL	0.31	0.31	0.45	59
	00005	Clr3/arg/RLE3, ss3 3 1/4" frame	VY	2	0.027 (3)	0.6250	OF-S	ARG	N		CL	0.27	0.35	0.51	62
	00005-00001	Clr3/arg/RLE3, ss3 3 1/4" frame	VY	2	0.027 (3)	0.6250	OF-S	ARG	G	0.75	CL	0.27	0.31	0.45	62
	00005-00002	Clr3/arg/RLE3, ss3 4 9/16" frame	VY	2	0.027 (3)	0.6250	OF-S	ARG	N		CL	0.27	0.35	0.51	62
	00005-00003	Clr3/arg/RLE3, ss3 4 9/16" frame	VY	2	0.027 (3)	0.6250	OF-S	ARG	G	0.75	CL	0.27	0.31	0.45	62
	00006	Clr2.5/air/RLE2.5, ss2 3 1/4" frame	VY	2	0.027 (3)	0.6870	OF-S	AIR	N		CL	0.31	0.35	0.51	59
	00006-00001	Clr2.5/air/RLE2.5, ss2 3 1/4" frame	VY	2	0.027 (3)	0.6870	OF-S	AIR	G	0.75	CL	0.31	0.31	0.45	59
	00006-00002	Clr2.5/air/RLE2.5, ss2 4 9/16" frame	VY	2	0.027 (3)	0.6870	OF-S	AIR	N		CL	0.31	0.35	0.51	59
	00006-00003	Clr2.5/air/RLE2.5, ss2 4 9/16" frame	VY	2	0.027 (3)	0.6870	OF-S	AIR	G	0.75	CL	0.31	0.31	0.45	59
	00007	Clr2.5/arg/RLE2.5, ss2 3 1/4" frame	VY	2	0.027 (3)	0.6870	OF-S	ARG	N		CL	0.28	0.35	0.51	63
	00007-00001	Clr2.5/arg/RLE2.5, ss2 3 1/4" frame	VY	2	0.027 (3)	0.6870	OF-S	ARG	G	0.75	CL	0.28	0.32	0.45	63
	00007-00002	Clr2.5/arg/RLE2.5, ss2 4 9/16" frame	VY	2	0.027 (3)	0.6870	OF-S	ARG	N		CL	0.28	0.35	0.51	63
	00007-00003	Clr2.5/arg/RLE2.5, ss2 4 9/16" frame	VY	2	0.027 (3)	0.6870	OF-S	ARG	G	0.75	CL	0.28	0.32	0.45	63

**NFRC Product Certification Authorization Report**

**IA:** Keystone Certifications, Inc.

**Manufacturer:** Best Window and Door Company  
**Product Series:** 3300/4300 Double Slider

**Street:** 332 Strayer Street  
**Type:** Horizontal Slider

**City/State/Zip:** Johnstown, PA 15906  
**CPD Number:** BES-K-3

**Baseline Information**

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TAIR	5/21/2003	47.25 X 59	0.29	0.27	NV-00260-L

**Comments:**

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature: \_\_\_\_\_